

## AUTOMATIC CHANGEOVER REGULATOR– NEW DESIGN CLESSE COMPACT 100 AND HP VERSIONS

Following in-service quality testing review and monitoring at Clesse it has been decided to recall product dated

**March 2008 to March 2009. - marked 0308 to 0309 inc.**

Clesse customers are offered a like for like exchange of regulator, using upgraded and modified design.

### Reason for exchange

There is a remote possibility under certain conditions that gas leakage from the changeover head component of the product may occur. However the regulator remains fully functional and provided the automatic changeover and cylinders are installed outside to current Codes of Practice, then leakage should not pose an immediate safety issue.



**Not Affected**—Compact 80 models or models Clesse 5165 (with cream coloured back-plate)

**If you have any of the above regulators for exchange -**  
Please contact

- Your gas installer or retailer who supplied the product
- On Park Home sites contact site management
- If you are the installer contact your Clesse distributor or register direct with Clesse (UK) Ltd phone or online
- If purchased mail order please contact your retailer.


**You can register your product for exchange on**

[www.clesse.co.uk/aco-recall/register](http://www.clesse.co.uk/aco-recall/register)  
Or phone Freephone 0800 158 55 11

<b>Visual Appearance</b>	<b>Model Number and Description</b>
	Low Pressure Regulator 37mb Automatic Changeover 5175C01,CO6, C20 COMPACT100 Clesse Brand  Date of manufacture July 2008 to March 2009
	High Pressure Regulator 1.5bar Automatic Changeover 8175000, 002635AE  Clesse and Novacommet Brand  Date of Manufacture March 2008 to March 2009 Novacommet brand please refer to website for details to identify

### **In Service Product**

Following registration via Clesse UK or your Clesse distributor, retailer, park manager or installer of your Automatic Changeover Regulator dated from March 08 to March 09, Clesse will make arrangements for this to be replaced by a qualified gas engineer, normally free of charge.



**Identifying product** Marked date of manufacture is etched on the product instruction panel as indicated above.

**Any product marked 0309 (March 09) or before this date should be replaced.**

Product marked after this date i.e. 0409 (April 09) does not require to be replaced. Additionally the letter A proceeds the G batch number for additional verification of a satisfactory product.

Novacommet branded product—please call or visit website for further information

**Clesse (UK) Ltd**, Unit 8, Planetary Road  
Industrial Estate, Planetary Road,  
Wolverhampton, WV13 3XQ  
Phone: 01902 383233 Fax: 01902 383234  
Email: [sales@clesse.co.uk](mailto:sales@clesse.co.uk)